

Gary W. Moore
County Judge-Executive

Jeffery S. Earlywine
County Administrator



Jerald E. Noran
Chief Building Inspector

THE BOONE COUNTY BUILDING DEPARTMENT

www.BooneCountyKy.org

2950 Washington Street (Suite 312) • P.O. BOX 960 • BURLINGTON, KENTUCKY 41005

(859) 334-2218 • FAX (859) 334-3137

A F F I D A V I T FOR GEO THERMAL INSPECTION

I, _____, do hereby confirm that I've witnessed at least 30 minutes of the GEO Thermal test located at:

Permit #: _____

Address: _____

Subdivision/Project Name: _____

SIGNATURE OF GENERAL CONTRACTOR
(Witness)

DATE

I further affirm that the work listed above meets or exceeds the requirements of the Kentucky Building/Mechanical Code. I further hold harmless the County of Boone and the County Building Inspectors as individuals as County Employees. I also assume all responsibility for any damage to any property as a result of the installation of these improvements and understand that this affidavit will remain as a permanent record with the Boone County Building Department.

Section M2105: The assembled loop system shall be pressure tested with water at 100 psi (690 kPa) for 30 minutes with no observed leaks before connection (header) trenches are backfilled. Flow rates and pressure drops shall be compared to calculated values. If actual flow rate or pressure drop figures differ from calculated values by more than 10 percent, the problem shall be identified and corrected.

SIGNATURE OF HVAC CONTRACTOR

DATE

SUBSCRIBED AND SWORN TO BEFORE ME BY _____

ON THIS _____ DAY OF _____, 20__

NOTARY PUBLIC
My commission expires: _____

APPROVED BY:

Jerald Noran, Chief Building Official