

APPENDIX "E"

WATER LINE SPECIFICATIONS

ITEM 1.0 GENERAL

- 1.01 GENERAL: Each applicant or developer shall follow the water specifications adopted by the appropriate water district. The water districts serving Boone County include the following:

Boone County Water District
P.O. Box 18
Burlington, Kentucky 41005
(859) 586-6155

Northern Kentucky Water Service District
2835 Crescent Springs Road
Erlanger, Kentucky 41018
(859) 578-9898

City of Florence
Public Services Department
8100 Ewing Blvd.
Florence, KY 40142
(859) 647-5416

Bullock Pen Water District
#1 Ferrell Drive
Crittenden, Kentucky 41030
(859) 428-1235

Walton Water Works
Church & Main Streets
Walton, Kentucky 41094
(859) 485-4383

- 1.02 All trenches within the Public Right of Way shall be backfilled with controlled low strength material (CLSM) (flowable fill) per the requirements of the applicable legislative body.